GOVT. OF HARYANA PUBLIC HEALTH ENGINEERING DEPARTMENT WATER TESTING LABORATORY, KARNAL-132 001

1. Sender's Address: Principal 2. Source of Sample: Uy S CR. O. Tracetal Shrinity Public Sch. Kuchwar at Sch. Cumpus.

3. Collected on :

3/6/19 (Byhimself) 4. Received on: 3/6/19

5. Ref. No.:

69716119 Mu Dt. 316/19

femo No.	419		Dated 4619		
Sr. no.	Substance/Characteristic	Result	Desirable Limit	Maximum Permissible Limit (in absence of better alternative source)	
			As per IS:10500-1991		
1	Colour, Hazen Units	Clear	5	25	
2	Odour	Hormal	Unobjectionable		
3	Taste	h	Agreeable		
4	Turbidity, NTU	Mu	5	-10	
5	Total Dissolved Solids, mg/1	170	500	2000	
6	Total Hardenss, mg/1	150	300	600	
7	Calcium (as Ca), mg/1	20	75	200	
8	Magnesium (as Mg), mg/1	ZA	30	100	
9	Alkalinity, mg/1	160	200	600	
10	Chloride (as Cl), mg/1	45	250	1000	
11	Fluoride (as F), mg/1	0.410	1.0	1.5	
12	Sulphate (as SO4) mg/1	10	200	400	
13	Nitrate (as NO3), mg/1	1.3	45	45	
14	Iron (as Fe), mg/1	<u>ru</u>	0.3	1.0	
15	Residual Chlorine, mg/1	4	0.2	0.5	
16	pH value	1-31	6.5-8.5	No. relaxn.	
17	Total/Feacal Coliforms	Ye	NII	10/Nil	

OPINION

The Physico-Chemical analysis indicates that above water sample is Blable for above tested Parameters

Parabele Parity

SAVE WATER-CONSERVE WATER-DO NOT POLLUTE IT.

HEALTH DEPARTMENT HARYANA, KARNAL

NO OBJECTION CERTIFICATE

Certifiy that the premises of In Janty Rublic School
Kaehwa Karnal
has been inspected. The campus of the institute has been found satisfactory
from Sanitation & Hygienic point of view.
Sd/-
Deputy Civil Surgeon (Health)
Karnal
No. GH.SSI/20 19 428 Dated 3.9.2019
A copy is forwarded to the for information and necessary action in
reference to his letter no for
information.
Principal Infinity Public School Bachura. Karnal.
Kachuta. Karnal.

Deputy; Civil Sergeon (Health Karna)

Karna

Rana